2018 CERTIFICATION Consumer Confidence Report (CCR) Public Water System Name List PWS ID #s for all Community Water Systems included in this CCR The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon must be mailed or delivered to the customers, published in a newspaper of notal customers, or provided the request. Make sure you follow the proper procedures when distributing the CCR. You must email, fex (but not preferred) or mails a copy of the CCR and Certification to the MSDE. Please check all boxes that apply. Customers were informed of availability of CCR by: (Anach copy of publication, water bill or other) ☐ Advertisement in local paper (Attack copy of advertisement) On water bills (Attach copy of bill) ☐ Email message (Email the message to the address below) Other Date(s) oustomers were informed: CCR was distributed by U.S. Poetal Service or other direct delivery. Must specify other direct delivery /2019 CCR was distributed by Email (Email MSDH e copy) Date Emailed: Asa URL As an attachment (Provide Direct URL) As text within the body of the email message CCR was published in local newspaper. (Attach copy of published CCR ar proof of publication) Date Published: CCR was posted in public places. (Amech list of locations) CCR was posted on a publicly accessible internet site at the following address: Date Posted; CERTIFICATION
I hereby seriffy that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true of Health, Bureau of Public Water Supply

A water Supply Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.) Date Submission options (Select one method ONLY) Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700 Email: water reports@madh.ma.ggy Jackson, MS 39215 Fax: (601) 576 - 7800 Not a preterred method due to poor clarity CCR Deadline to MSDH & Customers by July 1, 2019!

r ven. with the

2019 AUG -2 AM 7: 52

## 2018 Annual Drinking Water Quality Report Town of Beulah PWS#: 0060003 July 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Beulah have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Edward King at 662.458.0939. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular scheduled meetings held on Tuesday, 8/13/2019at 6:00 PM at the Beulah Town Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018 the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

				TEST RES	ULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Inorganic	Contam	inants						
10. Barium	N	2018	.004	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.276	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer an aluminum factories

17. Lead	N	2015/17	• 0	0	ppb		0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
		Products	S						
81. HAA5	N	2017*	2	No Range	ppb	0		60 By	-Product of drinking water sinfection.
Chlorine ————	N	2018	.6	.3690	mg/l	0	MDRL:	= 4 Wa	ater additive used to control

<sup>\*</sup> Most recent sample. No sample required for 2018.

Microbiological Contaminants:

(2) Fecal coliform/E.Coli. Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.

Disinfection By-Products:

Chlorine. Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

Our system received a monitoring violation for Chlorine for the period of 1/01/18 - 3/31/18 and for E. Coli for the period of 2/01/18 - 2/28/18. We also received a Consumer Confidence Report violation for not completing the CCR by the July 1 deadline.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

## Significant Deficiencies

Monitoring and Reporting of Compliance Data Violations:

During a sanitary survey conducted on 11/19/2014, the Mississippi State Department of Health cited the following significant deficiency(s):

Lack of redundant Mechanical Components Where Treatment is required

Corrective Actions: This system is out of compliance and subject to enforcement action. 12/14/17

Inadequate Follow Up on Previous Deficiencies

No Approved Emergency Response Plan or Vulnerability Analysis

Corrective Actions: This system is out of compliance and subject to enforcement action.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

We at Town of Beulah around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.